

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1615:179

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Model D6600 Netcom Digital Alarm Communication Receiver (DACR). Unit is intended for receiving alarm signals in a central monitoring station. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

D6600	Receiver
D6610	CPU Card
D6615	CPU Terminator Card
D6630	AC/DC Power Supply Module
D6631	DC/DC Power Supply Module
D6640	Telephone Line Card
*D6641	Line Card
D6645	Telephone Line Terminator Card
SC9002	External Printer
D6680-E120	Network Adaptors
D6672	Com 1 Expansion Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as digital alarm communication receiver for use with listee's separately listed Model C900TTL-E Dialer Capture Module and D9133TTL-E Network Interface Module (CSFM Listing No. 7300-1615:180) and Models D7212, D7412, D9112, D9412, D7412G, or D9412G fire alarm control units. D6600 may also be used with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

FORMERLY: 7300-0801:211

*Rev. 01-14-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division